

Important Information about your Drinking Water

Levels of Radium, (226 + 228) in Suamico Waterworks water exceed standard

The samples listed below indicate the presence of Radium, (226 + 228) in excess of the 5 pCi/L Maximum Contaminant Level (MCL) in your drinking water and are a violation of State and Federal Safe Drinking Water Regulations.

A water sample collected on May 26, 2015 from the Well 2 entry point, indicated the presence of Radium, (226 + 228) above the MC, which required Suamico Waterworks to sample quarterly. Further sampling on October 26, 2016, March 27, 2017, June 12, 2017 and September 26, 2017, confirmed the high levels of Radium, (226 + 228). The resulting running annual average is 5.7 pCi/L Radium 226+228.

What precautions should be taken at this time?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.

What is being done to correct the problem?

Corrective action(s) taken:


Well 2 shut down until
corrective actions can be completed or a
decision is made to remove well from service.

We are working to resolve this problem as soon as possible. We will notify you when the problem is resolved.

If you have questions regarding the safety of our drinking water, please contact:

Daniel S Drewery 920 434-8410
Name of Responsible Person Area Code-Telephone Number
12781 Velp Ave. Green Bay WI 54313
Street Address City State Zip

I certify that the information and statements contained in this public notice are true and correct and have been provided to consumers in accordance with the delivery, content, format, and deadline requirements in Subchapter VII of ch. NR 809, Wis. Adm. Code

X 
Signature

11-17-17
Date

Tier 2 Notice

** Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.